



Scott Walker, Governor
Dave Ross, Secretary

August 06, 2015

Identification Numbers
Transaction ID No. 2573366
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1323442

STEVE DAVIS
AK INDUSTRIES INC
PO BOX 640
PLYMOUTH IN 46563

PLAN APPROVAL EXPIRES: 08/06/2017

Re: Description: SEWAGE TANKS, POLYETHYLENE
 Manufacturer: AK INDUSTRIES, INC.
 Product Name: SEPTIC (trans id 2573366)
 Model Number(s): AKS 30249-300 GALLON
 (40 IN. L.L., 24 IN. MAX. DEPTH OF BURY, 144 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
 Product File No: 20150182

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2020.**

This approval supersedes the approval issued on 8/02/2010 under product file number 20100317.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- Tank Bedding: As per manufacturer's instructions, provide 6 to 12 inches of 3/8 to 3/4 inch gravel type aggregate or AK Industries Inc. approved aggregate.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction