



July 29, 2016

NORWESCO, INC.
ANASTASIA R. O'HARA
PO BOX 439
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: NORWESCO, INC.
Product Name: (tarns id 2741639) SEPTIC, PUMP, HOLDING OR SEPTIC/SEPTIC
Model Number(s): 1500 BSR
(52.25 IN. L.L., 36IN. MAX. DEPTH OF BURY, 716 G.P.D. WHEN USED AS A SEPTIC
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER;
TANK DIMENSIONS = 133 IN. L X 55 IN. W X 66 IN. H)
Product File No: 20160191

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.25 (7)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code.

This approval is valid until the end of July 2021.

This approval supersedes the approval issued on 5/25/2011 under product file number 20110176.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25 (8) (b), Wis. Admin. Code must be securely attached to the manhole cover.
- This tank must be filled up to 13 inches from bottom of tank after installation or when pumped empty and the lowest liquid level of the tank when used as a pump or holding tank must be 13 inches.
- When the optional divider wall is installed and the tank is used as a double compartment septic tank (ST) /ST, there shall be a separator wall with 4 5/8-inch hole through to the second compartment. The second compartment shall allow the installation of an effluent filter. This option is not for use as a ST/PC (pump chamber).

NORWESCO, INC.
Page 2
July 29, 2016
Product File No: 20160191

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction