



July 29, 2016

NORWESCO, INC.
ANASTASIA R. O'HARA
PO BOX 439
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: NORWESCO, INC.
Product Name: (trans id 2741645) LOW PROFILE SEPTIC, PUMP OR HOLDING TANK
Model Number(s): 750 2 MH 1 CPT, LOW PROFILE
(40 IN. L.L., 36 IN. MAX. DEPTH OF BURY; 342 G.P.D. WHEN USED AS A SEPTIC TANK
BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK
DIMENSIONS (OD) = 92 IN. L X 60 IN. W X 51 IN. H)
Product File No: 20160192

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.25 (7)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code.

This approval is valid until the end of July 2021.

This approval supersedes the approval issued on 4/27/2016 under product file number 20130341.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is labeled with a sticker that contains the following information: CAPACITY IN GALLONS, along with other manufacturer's information.
- BEDDING AND BACKFILL: See attachment B, LP Underground Tank Installation Instructions, 2 pgs.
- LABELING: This device must include permanent labeling; identified by manufacturer, model and serial number, affixed to the device in view of inspection.

NORWESCO, INC.
Page 2
July 29, 2016
Product File No: 20160192

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction