



Scott Walker, Governor
Dave Ross, Secretary

December 16, 2016

Identification Numbers
Transaction ID No. 2799698
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1168462

AK INDUSTRIES INC
PO BOX 640
PLYMOUTH IN 46563

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 12/31/2021

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: AK INDUSTRIES, INC.
Product Name: (trans id 2799698) PUMP
Model Number(s): AKS 20580 -- 750 GALLON

(50 IN. L.L., 24 IN. MAX. DEPTH OF BURY, TANK DIMENSIONS = 87.5 IN. DIA. X 48.5 IN. H; SEE ATTACHMENT FOR GALLON CAPACITY AT SPECIFIED LEVELS FOR 750 GAL. TANK)

Product File No: 20160304

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of December 2021.**

This approval supersedes the approval issued on 10/26/2011 under product file number 20110314.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- A minimum 2" diameter vent must be provided on the building sewer within 12" of the connection to the tank or on the tank installed in accordance with the manufacturer instructions.
- **BACKFILL:** Course sand or fine gravel backfill of 1/2 in. or smaller must be used and completely surround and cover the tank within one-foot or less of the ground surface.
- **BEDDING:** Compacted aggregate conforming to tank base at depth and diameter as per manufacturer's installation instructions; dewater excavation prior to installation.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov