



August 03, 2017

Identification Numbers
Transaction ID No. 2960798
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1323442

STEVE DAVIS
AK INDUSTRIES INC
PO BOX 640
PLYMOUTH IN 46563

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 08/31/2022

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: AK INDUSTRIES, INC.
Product Name: (trans id 2960798) QTS LOW PROFILE 1050 GAL. SEPTIC TANK/BAFFLED/20&20 LID, SEPTIC
Model Number(s): AKS-50705
(40 IN. L.L., 24 IN. MAX. DEPTH OF BURY, 507 G.P.D. WHEN USED AS SEPTIC TANK BASED ON 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 125.75 IN. L X 67 IN. W X 40.0 IN. H)
Product File No: 20170182

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2022.**

This approval supersedes the approval issued on 8/30/2012 under product file number 20120330.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product may only be used as a septic tank.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The inlet, outlet and tees must be schedule 40 PVC conforming to ASTM standard D2665 or D1785.
- The tees must be installed so that they extend a minimum six inches above the liquid level, nine inches below the liquid level but not more than 1/3 below the liquid level of the tank and have at least two inches of clearance between the top of the tee and the tank.

- The tees must be located between the end wall and the center line of the manhole on one end of the tank and between the end wall and the center line of the 10 inch observation pipe on the other end of the tank.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- BACKFILL: Course sand or fine gravel backfill of ½ in. or smaller must be used and completely surround and cover the tank within one-foot or less of the ground surface.
- BEDDING: Compacted aggregate conforming to tank base at depth and diameter as per manufacturer's installation instructions; dewater excavation prior to installation.
- LIDS AND RISERS: Romar risers/lids and covers available in variable heights.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov