



October 24, 2017

NORWESCO, INC.
ANASTASIA R. O'HARA
PO BOX 439
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: NORWESCO, INC.
Product Name: (trans id 3015072) SEPTIC
Model Number(s): 1000
 (46.25 IN. L.L., 36 IN. MAX. DEPTH OF BURY; 479 G.P.D. BASED ON A 3 YR. SERVICE
 INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20170252

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2022.

This approval supersedes the approval issued on February 15, 2013 under product file number 20120376.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product may only be used as a septic tank.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD₅ greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Before this product is installed a warning label meeting the requirement of s. SPS 384.25 (8) (b), Wis. Admin. Code must be securely attached to the manhole cover. The warning label shall be visible after installation.
- Covers located at, or above grade, for all openings \geq 8 inches in diameter shall be provided with locking devices or other effective means to preclude unauthorized access.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Norwesco Inc.
October 24, 2017
Page 2 of 2
Product File No.: 20170252

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail